Energies Barbarted Ground Hospital Grade Receptacle



MODEL NO: 61610

DESCRIPTION

Hospital grade receptacles meet UL hospital grade requirements. In addition to complying with the general use receptacle listing requirements, hospital grade devices incorporate additional construction features and are subjected to additional performance requirements. These include grounding reliability, assembly integrity and strength and durability tests.

FEATURES	SPECIFICATIONS	
 Impact resistant thermoplastic cover and body Ground termination-brass strap version Break-off tabs for easy two-circuit conversion Two side barriers cover the wire terminals for insulation and isolation function Use only with 10AWG to 14AWG wires 	Amperage Voltage NEMA Termination Material Operating Temperature Warranty	15 Amp 250VAC 6-15R Back Wired Thermoplastic -104° F to 167° F 2 Years

TESTING & CODE COMPLIANCE



APPLICATIONS

- Health Care Facilities
- Hospitals
- Laboratories

SPECIFICATION SUBMITTAL

Control. Charge. Connect.	16 🚖 +1 (949) 756-0528 🗳 sales@enerlites.com	REV-20230802
Notes		
Job Name	Job Number	